

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7315-1725:0108

CATEGORY: 7315 -- POWER UNITS

LISTEE: STANLEY SECURITY SOLUTIONS 6161 E. 75th Street, Indianapolis, IN 46250
Contact: Robert Strong (317) 806-3288 Fax (317) 806-3337
Email: bob.strong@sbdinc.com

DESIGN: Model PS161-6 supply/charger. Model number may be followed by additional alpha suffix indicating enclosure color. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 V, 60 Hz, 3.5 A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a power supply/charger unit for use with separately listed compatible fire alarm control units for indoor use only. Refer to listee's Installation Instruction Manual for details.

XLf: 7315-1335:0126

06-23-14 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division