

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 3775-1725:0107

CATEGORY: 3775 -- MANUAL LOCKS

LISTEE: dormakaba USA Inc. 6161 E. 75th Street, Indianapolis, IN 46250
Contact: Robert Strong (317) 903-1486 Fax (317) 806-3337
Email: bob.strong@dormakaba.com

DESIGN: Models 83K, 84K, 85K, 93K, 94K and 95K. May be used on fire doors rated 3 hours of less in sizes up to 4 Ft. in width and 10 Ft. in height. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as fire-rated locks. Refer to Manufacturer's Installation Instruction Manual for details.

NOTE: Formerly 3775-1175:0111

4-2-10 MA



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division