

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 3776-1725:0502 Page 1 of 1

**CATEGORY:** 3776 -- ELECTRIC DOOR STRIKES/POWER SUPPLY

**LISTEE:** dormakaba USA Inc. 6161 E. 75th Street, Indianapolis, IN 46250  
Contact: Robert Strong (317) 903-1486 Fax (317) 806-3337  
Email: bob.strong@dormakaba.com

**DESIGN:** Model BES-F2164 Electric door strike and may have the following suffixes denoting faceplate finish or plating: 3, 4, 10, 10B, 32, or 32D. Operation of strike is only FAIL SECURE. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 3hr for single swing door, 4'-0" X 8'-0" maximum  
90 minute for standard double doors, 8'-0" X 8'-0" maximum

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, fire rating, electrical rating, UL label.

**APPROVAL:** Listed as a fire rated electric strike for use only in applications permitted to have fail secure locking per the California Building Code. Authority having jurisdiction shall be consulted prior to any installations. Refer to listee's Installation Instructions Manual for details.

**XLf:** 3776-2275:0502

12-04-18 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **VICTOR WONG, Program Coordinator**  
*Fire Engineering Division*