

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 3774-1725:0503

Page 1 of 1

**CATEGORY:** 3774 -- ELECTRIC LOCKS

**LISTEE:** dormakaba USA Inc. 6161 E. 75th Street, Indianapolis, IN 46250  
Contact: Robert Strong (317) 903-1486 Fax (317) 806-3337  
Email: bob.strong@dormakaba.com

**DESIGN:** Models BML-8310, BML-8320, BML-8371, BML-8372, and BML-8380 electromagnetic auxiliary locks. The Model designation may be followed with a suffix which indicate the following sensor options:

DSS - Door Status Sensor  
SCS - Security Condition Sensor  
DSS/SCS - Door Status/Security Condition Sensor

Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as auxiliary electric door locks for use with swinging type doors. Authority having jurisdiction should be consulted prior to any installations. Refer to listee's Installation Instructions Manual for details.

**XLF:** 3774-2275:0500

12-04-18 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **VICTOR WONG, Program Coordinator**  
*Fire Engineering Division*