

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7315-1725:0101

Page 1 of 1

CATEGORY: 7315 -- POWER UNITS

LISTEE: dormakaba USA Inc. 6161 E. 75th Street, Indianapolis, IN 46250
Contact: Robert Strong (317) 903-1486 Fax (317) 806-3337
Email: bob.strong@dormakaba.com

DESIGN: Model PS-160-6 Power Supply Unit. Unit is a power supply with an MOM5 multi-output power module. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 115 VAC input, 12 or 24 VDC output

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as power supply units for use with separately listed compatible fire alarm control units. Also suitable for use with access control systems. Authority having jurisdiction should be consulted prior to installation.

NOTE: For fire alarm use, the standby batteries must provide at least 24 hours standby power during power loss. The battery circuit must be fully supervised.

XLF: 7315-1335:0104

2-19-09 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division