

GXHX7.R7639 - Fire-exit Hardware Certified for Canada

Fire-exit Hardware Certified for Canada

dormakaba USA Inc

6161 E 75TH ST

PO BOX 50444

INDIANAPOLIS, IN 46250 United States

R7639

Investigated to ANSI/BHMA A156.3 (2001) Grade 1**Concealed vertical rod devices** Model(s) FL2600 (d), FL2700 (d), FL2800 (d)**Single-point mortise latches** Model(s) FL2300 (e), FL2303 (e), FL2310 (e), FL300 (a)**Single-point rim type latches** Model(s) FL100 (b), FL21 (f), FL2100 (f), FL2103 (f), FL2110 (f), FL2400 (c), FL51 (f), FLR100 (b)**Surface mounted vertical rod devices** Model(s) FL22 (d), FL2200 (d), FL52 (d)**Surface-mounted vertical rod devices** Model(s) FL200 (a), FL200LBR (a)**Investigated to ANSI/BHMA A156.3 (2008) Grade 1****Concealed vertical rod devices** Model(s) ESF9100+(a), ESF9600+(a), F4100*(a), AD4100*(a), F5100*(a), F6100*(a), F9100+(a), F9100LB+(a), F9600+(a)**Single point mortise locks** Model(s) ESF9500%(a), F4500 (a), F5500 (a), F9500%(a)**Single point rim type latches** Model(s) ESF9300%(c), ESF9700%(c), F6300 (b), F9300%(c), F9700%(c)**Single point rim type latches, may be supplied with a mullion** Model(s) F4300, ADF4300, F5300, F8300%**Surface mounted vertical rod devices** Model(s) F4400*(a), ADF4400*(a), F5400*(a), F6400*(a), F8400*(a), ESF9400+(a), ESF9400LB+(a), ESF9800+(a), F9400+(a), F9400LB+(a), F9800+(a)**Investigated to ANSI/BHMA A156.3 (2014) Grade 1****Concealed vertical rod devices** Model(s) QED 126, QED 129**Fire rated concealed vertical rod devices (3hrs., max 8ft. in width and height)** Model(s) QED226-CVR, QED229-CVR-LBR**Fire rated surface mounted vertical rod devices (3hrs., max 8ft. in width and height)** Model(s) QED216-SVR, QED219-SVR-LBR**Single point rim type latches** Model(s) QED213 (g)**Surface mounted vertical rod type latches** Model(s) QED 316, QED 319**Surface mounted vertical rod type latches (max. 10ft. height)** Model(s) QED 116, QED 119**Investigated to ANSI/BHMA A156.3 (2014) Grade 1, CAN/ULC S104, CAN/ULC S132****Rim types** Model(s) SGPD200F (h), SGPD250F (h)**Investigated to CAN/ULC S104****Single-point rim type latches** Model(s) FLHC2100 (f)**Concealed vertical rod devices** Model(s) ESBF9100+(a), ESBF9600+(a), ESF4100*(a), ADESF4100*(a), ESF5100*(a), ESF5100LB*(a), ESF6100*(a), ESF6100LB*(a), ESF9100LB+(a), ESF9600LB+(a), F4100LB*(a), F5100LB*(a), F6100LB*(a), F9600LB+(a)**Rim exit devices** Model(s) QED113 LR, QED313 LR**Single point mortise locks** Model(s) ESBF9500%(a), F6500 (a)

Single point rim type latches Model(s) ESBF9300%(c), ESBF9700%(c), ESF6300 (b), QED 113 (g), QED 313 (g)

Single point rim type latches, may be supplied with a mullion Model(s) ESF4300, ADESF4300, ESF5300, ESF8300%

Surface mount vertical rod exit devices Model(s) QED116 LR, QED316 LR

Surface mounted rolling bolt devices (rated up to 3, 1-1/2 or 3/4 hr.) Model(s) A101-FO1, A101-FO2, ARM-A-DOR

Surface mounted vertical rod devices Model(s) ESF4100LB*(a), ESF4400*(a), ADESF4400*(a), ESF4400LB*(a), ESF5400*(a), ESF5400LB*(a), ESF6400*(a), ESF6400LB*(a), ESF8400*(a), ESF8400LB*(a), F4400LB*(a), F5400LB*(a), F6400LB*(a), F8400LB*(a), ESBF9400+(a), ESBF9800+(a), ESF9800LB+(a), F9800LB+(a)

% - Models meet the requirements of the California Building Code (2013) Sec. 11B-309.4.

(a) - For use on single swinging doors rated up to and including 3 hrs not exceeding 4 ft. in width and 10 ft. in height.

(b) - May be supplied with FL822, FLKR822, QRM113, QRM313, QRM113HC, QRM113KR, QRM313KR or QRM113HCKR removable mullions for doors rated up to and including 3 hrs, not exceeding 8 ft in width and height.

(c) - Rated up to and including 3 hrs not exceeding 4 ft. in width and 10 ft. in height; may be supplied with FL822, FLKR822, QRM113, QRM313, QRM113HC, QRM113KR, QRM313KR, and QRM113HCKR removable mullions for doors rated up to and including 3 hrs, not exceeding 8 ft in width and height. May be prefixed with DE, MLR or ELR. May be suffixed with ALK or ALW.

(d) - Rated up to and including 3 hrs not exceeding 4 ft in width and 10 ft in height. May be prefixed with DE, MLR or ELR. May be suffixed with ALK, ALW or LBR.

(e) - Rated up to and including 3 hrs not exceeding 4 ft in width and 10 ft in height. May be prefixed with DE, MLR or ELR. May be suffixed with ALK, ALW or E.

(f) - Rated up to and including 3 hrs not exceeding 4 ft in width and 10 ft in height; may be supplied with HC822, FL822 or FLKR822 removable mullions for doors rated up to and including 3 hrs, not exceeding 8 ft in width and height. May be prefixed with DE, MLR or ELR. May be suffixed with ALK or ALW.

(g) - Rated up to and including 3 hrs, not exceeding 8 ft in width and height. May be supplied with HC822, FL822, FLKR822, QRM113, QRM313, QRM113HC, QRM113KR, QRM313KR or QRM113HCKR removable mullions for doors.

(h) - Investigated to Sec. 11B-309.4 of the California building code.

* - May be followed by XTR.

+ - May be followed with FL.

Note - Lever handles for use as an outside trim may be provided and can be made from aluminum, brass, steel or stainless steel.

Trademark and/or Tradename:     

Last Updated on 2021-05-20

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2022 UL LLC"