



**LISTING REPORT - MANUFACTURING**

Issued: Jul 28 2010 11:04AM

Inspection Tests And Evaluation Of

**Securitech A4L Series Mortise Lock (22678)**

RENDERED TO  
**Securitech Group, Inc.**  
**54-45 44th Street**  
**Maspeth, NY 11378**

**GENERAL:** This Report gives the results of the inspection, tests and evaluation of the above for compliance with applicable requirements of the following standards : CAN4 S104 (1985) : NFPA 252 (2008) : UL 10(c) (2009)

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## PRODUCT DESCRIPTION

### Product Covered:

Securitech A4L Series Mortise Lock

### Product Description:

#### PRODUCT DESCRIPTION

A4L Series mortise lock approved for installation in up to 3 hour fire rated doors.

#### LIMITATIONS

Maximum size of door

4'0" wide x 8'0" high

Swing

Inswing or outswing, Single only

Latch Throw

Minimum 3/4"

| <u>Attribute</u>    | <u>Value</u>                    |
|---------------------|---------------------------------|
| CSI Code            | 08 70 00 Hardware               |
| Fire Resistance     | 20 Min w/Hose Positive Pressure |
| Fire Resistance     | 45 Min Positive Pressure        |
| Fire Resistance     | 90 Min Positive Pressure        |
| Fire Resistance     | 60 Min Positive Pressure        |
| Fire Resistance     | 3 Hour Positive Pressure        |
| Listed or Inspected | LISTED                          |
| Report Number       | 100062203MID-004                |
| Criteria            | CAN4 S104 (1985)                |
| Criteria            | NFPA 252 (2008)                 |
| Criteria            | UL 10(c) (2009)                 |